

Ministry of Business, Innovation and Employment

Embedded Hydro Generation Opportunities in New Zealand



Version 1.2: Final
2 October 2020
Roaring40s Wind Power Ltd



Document Control

Revision No.	Date	Revision Details	Author
1.0	14 August 2020	Draft for review	SH/GM
1.1	29 September 2020	Update draft for review	SH/GM
1.2	2 October 2020	Final	SH/GM

Table of Contents

- 1. Introduction..... 4
- 2. Objective..... 5
- 3. Hydropower Basics..... 5
 - 3.1. Types of hydropower schemes..... 7
- 4. Methodology 8
 - 4.1. Identifying potential sites for new embedded hydro generation 8
 - 4.1.1. Dataset identification (Step 1)..... 10
 - 4.1.2. GIS modelling process (Step 2) 12
 - 4.1.3. Automated thinning exercise (Step 3)..... 15
 - 4.1.4. Manual filtering exercise (Step 4)..... 15
- 5. Literature review 16
- 6. Results 16
- 7. Data Limitations..... 19
- 8. Final thoughts..... 22
- 9. About the authors 22
- 10. References..... 23

1. Introduction

The Ministry of Business, Innovation and Employment (MBIE), with support from Transpower, has engaged Roaring40s Wind Power Ltd (R40s) to provide an updated assessment of potential small scale embedded hydro electricity generation in New Zealand.

The future of the New Zealand (NZ) electricity system has been the focus of a number of studies in recent years with reports undertaken by Transpower¹, the Interim Climate Change Committee (ICCC)², MBIE³ and the Productivity Commission⁴ being the most noteworthy. These reports address the growth of NZ's electricity market (out to 2035 in the ICCC report and to 2050 in the other reports) and what this means in regards to NZ's electricity demand - and mix of technologies - as it moves towards a 100% renewable generation goal and a low carbon economy.

Transpower's most recent modelling work undertaken for their March 2020 report *Whakamana i te Mauri Hiko* assessed a range of different electricity demand forecast scenarios. These forecast scenarios suggest an increase from New Zealand's current electricity demand of ~40 TWh/annum to between 56 and 80 TWh/annum by 2050. This range aligns with the modeling work undertaken by the other parties. Figure 1 shows actual demand between 1998 to 2018 and various modelled scenarios by MBIE and Transpower between 2018 to 2050. Also plotted is an extrapolation from the 2018 actual demand to the upper estimate of the ICCC forecast – which was modelled as being 57 TWh/annum by year 2035.

During the course of writing this report, Rio Tinto announced their intent to close the Tiwai Aluminium smelter (NZAS) in August 2021⁵. This will mean a reduction of 5 TWh/annum, or 13%, of NZ's electricity demand. Transpower's 'Tiwai Exit' scenario, modelled for the *Whakamana i te Mauri Hiko* report and included on Figure 1, can thus be considered the most plausible of the future demand scenarios - assuming the smelter does close, but with a 'staged exit'⁶ over a five-year period between 2020 – 2025. This scenario shows:

- a decrease in electricity demand between 2020 and 2025;
- a recovery in electricity demand back to 2020 levels by 2029, and;
- significant growth (at the same rate as the Transpower Accelerated Electrification scenario) over the subsequent 20 years to give a total demand of approximately 65 TWh/annum by year 2050

Large-scale hydropower development in New Zealand was prolific between 1950 – 1980 but has decreased markedly since then. In fact, there have been no new large-scale schemes constructed since the Clyde Power Station (commissioned in 1992). Since this time there have also been a number of National Water Conservation Orders (NWCO) sought and approved (see Appendix A), many of which were specifically sought to prohibit the consideration of new hydroelectric development. This, combined with the higher value and competition for fresh water in New Zealand than there was 30 years ago means that the number of potential opportunities for new large-scale hydro generation in New Zealand is now quite limited.

Embedded generation refers to plants that, instead of being connected to the grid, are connected to a distribution network or are operated independently of any network. As such, they are constrained to

¹ Transpower (2018). Te Mauri Hiko – Energy Futures (White Paper), which has since been superseded by the March 2020 report *Whakamana i te Mauri Hiko*.

² ICCC (2019). Accelerated electrification: Evidence, analysis and recommendations, Interim Climate Change Committee.

³ New Zealand Government [MBIE] (2018). Electricity Price Review Hikohiko Te Uira. First Report for Discussion.

⁴ New Zealand Productivity Commission (2018). Low-emissions economy – Final Report.

⁵ https://www.nzas.co.nz/files/3413_2020070981142-1594239102.pdf.

⁶ A 'staged exit' being one that would see a reduction in the smelter operations (and electricity consumption) over a period of years, as opposed to the total 'hard exit' in August 2021.

being relatively small in size, usually less than 10MW. In the past the potential for embedded generation has not been given a great deal of attention in an overall electricity market sense. However, given the limited opportunities for new large scale hydro plant and the anticipated significant demand required over the new few decades as previously described, it is prudent to consider the potential that embedded hydro generation may have in meeting future demand growth.




Figure 1. NZ Electricity Demand Forecasts

2. Objective

The objectives of this assessment in relation to the identification of potential embedded hydro generation are to:

- Identify the potential total capacity for new (and locally embedded) hydro generation in New Zealand through the identification of potential sites that are greater than 1MW in capacity⁷.
- Provide the following details on each site:
 - Rated capacity (MW).
 - Annual generation (GWh).
- Summarise the findings in a report including a description of the methodology employed to identify the potential sites.

3. Hydropower Basics

The basic concept of hydropower generation is relatively simple – flowing water, being transported in a pipe (or penstock) is used to turn a *turbine*, which converts the kinetic energy of the flowing water into mechanical energy, turning a rotor inside a stator (being the components of the *generator*) which converts the mechanical energy into electrical energy (Figure 2). The greater the kinetic energy, the greater the mechanical energy and consequentially, the greater the electrical energy produced by the generator. The amount of kinetic energy in the water is dependent on the volume of water and the distance it falls – with gravity being the driving force.

⁷ This threshold was specified by MBIE in the commissioning of this work to constrain the scope of analysis.




Figure 2 Conversion of kinetic energy into electrical energy in a hydropower plant

The formula for calculating the theoretical potential power generated by hydropower is;

$P = m * g * h$ [Equation1] Where:

P = Power, measured in Watts (W).

m = the mass of the water - as a rate of flow (kg/s - numerically the same as the flow rate in litres per second because 1 litre of water weighs 1 kg).

g = the gravitational constant (which is $9.81m/s^2$).

h_{gross} = the gross head – being the difference in elevation between the intake and the discharge (i.e. the vertical distance over which the water drops).

There are energy losses through the various components of a hydropower system and these must be factored into the above equation to reflect applications in practise. The energy losses relate to water energy loss from wall friction (in the penstocks), turbine losses, generator losses, mechanical losses between the turbine and generators, and losses from the transformer and other power conditioning inefficiencies.

As such, the *practically available power* can be expressed as;

$P = m * g * h_{net} * \eta$ [Equation 2] Where:

h_{net} = the net head, being the gross head less any head losses. The head losses are mostly due to friction between the flowing water and the (inner) surface of the penstock, which increases with the number and angle of any bends. For the purposes of this study we have assumed the same head loss (10%) for all potential schemes identified. As such $h_{net} = h_{gross} * 0.9$.

η = the product of all of the other component efficiencies (the turbines, drive shaft, generator and transformer) which are typically all located in the powerhouse. The efficiencies of these components will vary slightly between different equipment, with the difference in turbine efficiency exhibiting the greatest variation (~80-95%)⁸, as the types of turbines can be quite different. For the purpose of this study we have assumed an overall total efficiency of 75%⁹ for all potential schemes identified, comprised as per the following breakdown;

- Turbine: 85%;
- Drive Shaft: 95%
- Generator: 95%
- Transformer: 98%

Note that in addition to the above losses there would also be transmission and distribution losses – being those losses associated with the conveyance of electricity between the point of generation and the point of connection to the electricity network/grid. The amount of these losses is dependent on the distance between the site and the point of connection, as well as the voltage of the electricity being exported. We have not attempted to quantify these losses as part of this study. As such, the generation potential for schemes identified in this report are at the point of export from each scheme’s powerhouse.

3.1. Types of hydropower schemes

There are two main types of hydropower schemes – ‘impoundment’ and ‘run-of-river’ (Figure 3). Impoundment schemes involve a reservoir as the water source, either naturally occurring (i.e. a lake) or man-made, typically created by the damming of rivers (see Figure 3). They often have very large capacities - hundreds or even thousands of MW, with the Three Gorges Dam scheme in China being the largest, at 22,500 MW¹⁰. Such large capacities are made possible by the stored water and the ability to control the flow of water entering and exiting the storage reservoir. They are usually connected to high voltage transmission grids – something which is necessary, due to their capacity. In New Zealand, there are many examples of large impoundment schemes, such as those on the Waitaki, Waikato, and Clutha rivers¹¹.




Figure 3 Types of hydropower schemes.

⁸ <https://www.sciencedirect.com/science/article/pii/S1876610214007395>

⁹ <https://www.sciencedirect.com/science/article/pii/S2211467X19300409>

¹⁰ <https://www.statista.com/statistics/474526/largest-hydro-power-facilities-in-the-world-by-generating-capacity/>

¹¹ There is an argument that many of New Zealand’s large hydro plant are essentially run-of-river because of their limited storage – but the distinction being made is that if they impound the river to create a reservoir of significant size then they are technically not run-of-river.

In general, impoundment schemes have a pronounced effect on the rivers' characteristics, particularly in situations where man-made dams are constructed to create artificial reservoirs upstream. Downstream effects are dependent on the scheme and the conditions of consent in relation to the residual (or environmental) flows.

In contrast to large scale impound type hydro schemes, run-of-river schemes are generally much smaller than impound schemes and are designed within the constraints imposed by the natural variations in river flows. Such schemes are still being investigated and constructed by developers in New Zealand – with Trustpower and Pioneer Generation being the most active.

Run-of-river schemes typically take a proportion of the natural river flow by way of a weir or a diversion channel and leave a residual (or environmental) flow in the river channel immediately downstream. The 'dewatered' section of the river is limited to the section between the intake and the discharge at which point river flows return back to their 'normal' flow volumes.

While it can be argued that a weir across a river will essentially impound it, the key difference between true impoundment schemes and run of river schemes is in their storage potential. Run-of river schemes will essentially have no, or only very limited, storage - whereas impoundment schemes may have the ability to capture and store river inflows in their reservoirs over weeks or even months and the ability to control and vary the volume of water being released downstream. Water releases range from just residual flows to full generation flow during periods of higher electricity demand.

Some run-of-river schemes incorporate a limited amount of 'man-made' water storage to augment power station flows when natural river flows are lower than usual. However, the storage is typically limited, and may only be large enough to enable a more attractive diurnal pattern of generation - with generation occurring when electricity demand is high, and storage of water when electricity demand is low. Whether a run-of-river scheme has the potential for having storage is very dependent on the topography of the site and the ability to create a storage pond close to the weir/diversion that is not cost prohibitive.

4. Methodology

For the purposes of this study, we have deemed it appropriate to focus solely on the identification of run-of-river schemes. Firstly, such schemes are more commonly associated with small-scale hydro generation – the identification of which is an objective of this study. Secondly, we believe that run-of river schemes are more likely to be successful in obtaining resource consent approval than impoundment type schemes – due to their reduced impact on the environment and less conflict with other stakeholders and consumers of the resource.

4.1. Identifying potential sites for new embedded hydro generation

The purpose of this study is to identify the potential of new embedded hydro generation greater than 1MW in capacity. As can be determined from Equation 2 in Section 3, there are only two variables (head and mass/flow) that need to be identified to calculate the potentially available power from a hydropower scheme – given that *gravity* is a constant and the operational *efficiencies* are being treated as constants. It is also apparent that the greater the volume of water (mass) and/or the greater the amount of head, the greater the generation will be. As the objective of this study is to identify potential sites that could generate at least 1MW, the following simple relationship between head and flow (in order to generate 1MW) can be derived.




Figure 4 Relationship between Flow and (gross) Head to generate 1MW

The relationship in Figure 4 is based on Equation 2 and has combined the constants – being gravity and the various losses (head, turbine, generator, drive shaft and transformer losses) into a single constant, 6.64. A simple way of interpreting the relationship is to multiply the flow by the head for the line described by the relationship. For instance, a flow through the power station of 3 cumeecs¹², will need to have a head of ~50m to generate 1MW (i.e. 3 * 50 * 6.64 = 996kW, or 0.996 MW). Not surprisingly, if you halve the flow (to 1.5 cumeecs) the head would have to double (to ~100m) to be able to generate 1MW. In summary, and based on the losses that we have determined as being appropriate, any product of flow*head that is greater than 150.66 will be able to generate at least 1MW (once the constant of 6.64 is factored in). This is a useful way of understanding the minimum requirements of flow and head that must be met to achieve the objective of at least 1MW generation.

However, it is also important to consider construction cost. There is no point in identifying theoretical sites that meet flow and head criteria in isolation of construction difficulty/cost. Unlike large impoundment schemes where the majority of the cost concerns the construction of the dam/embankment, a significant proportion (up to 50%) of the cost for run-of-river schemes is typically attributable to the diversion channel and penstocks between the intake and powerhouse (Zhang, 2012).

It is also apparent when comparing two schemes which have the same flow and head, that these will have the same generation potential and thus will essentially have the same costs for the powerhouse and equipment within it. However, if the distance between the intake and powerhouse differs and Scheme A has a longer or more difficult conveyance route than Scheme B, the construction cost of Scheme A will be greater due to this difference. The head losses will also be greater for Scheme A. As such, it is highly desirable to identify schemes with shorter and more direct conveyance routes.

Thus the identification of potential schemes is not only based on a product of flow and head, but also the criteria that the required minimum head must be achieved within a specified distance. The following steps were undertaken to identify potential schemes:

1. Identify the appropriate datasets to be used in the analysis and identify the appropriate search criteria including the distance (between intake and discharge) over which the required combination of head and flow must be met.

¹² One cumeec = one cubic meter per second (also expressed as 1 m³/s) = 1000 litres per second

2. Develop a Geographic Information System (GIS) process to identify locations on rivers that have the necessary combination of head and flow within the specified distance to generate at least 1MW.
3. Perform an automated “thinning” exercise to reduce the number of potential locations of hydro generation in close proximity to each other by identifying the ‘best’ or most optimal.
4. Perform a manual filtering exercise in GIS to identify valid potential sites by:
 - a. Removing sites within National Parks.
 - b. Removing sites within rivers subject to NWCO.
 - c. Removing sites coincident with existing hydro generation already in operation.
 - d. Identifying the optimal site where two or more potential results are not compatible with each other (and removing those sites that are sub-optimal).
 - e. Removing sites that are considered logistically impractical from an access or construction perspective.

These steps are described in detail in the following sections.

4.1.1. Dataset identification (Step 1)

As described previously, two key variables – head and flow are required. A third variable, conveyance distance – being the distance over which the head criteria must be met – is also an important aspect to consider in the identification of potential schemes to ensure the results are logical and valid.

Head

In consideration of the extent and dataset size, the most appropriate source of information for this study was determined as being the Land Information of New Zealand (LINZ) 8m Digital Elevation Model (DEM). This dataset, covering the entire country, contains elevation spot heights on an 8m spaced grid. The dataset was created in 2012 by the interpolation of the LINZ 20m contours¹³. The description of the dataset in the metadata notes that “*Spatial accuracy is nominally the same as for the LINZ source data: 90% of well-defined points are within ±22 metres horizontally and within ±10 metres vertically*”. Although this level of accuracy is not as high as would have been desired (as discussed in Section 7), alternative datasets of higher accuracy covering the entire country do not exist. A detailed description of this dataset can be found in the metadata on the LINZ website¹⁴.

Flow

Following a search of publicly available data, the National Institute of Water and Atmospheric Research (NIWA) “River Flows” dataset was determined as the most appropriate dataset. This dataset contains flow information on every section of river in New Zealand. It is based on data records of more than five years duration at 485 hydrological stations across New Zealand which have been used to extrapolate, through modelling, to provide hydrological river flow parameters for over 576,000 specific river segments. A detailed description of this dataset can be found in the metadata on the MfE website¹⁵ and Appendix E contains an image identifying the locations of the 485 hydrological stations used in the modelling.

The river segments are segregated where tributaries intersect – which is logical, as river flows increase downstream of where tributaries join. This ensures that the flow characteristics within each segment are consistent. River segment lengths range from 30m to 13km in the North Island and 30m to 29km in the South Island, with the vast majority being less than 5km in length.

¹³ The 8m Digital Elevation Model (DEM) was originally created by Geographx (geographx.co.nz) and was primarily derived from January 2012 LINZ Topo50 20m contours.

¹⁴ <https://data.linz.govt.nz/layer/51768-nz-8m-digital-elevation-model-2012/metadata/>

¹⁵ <https://data.mfe.govt.nz/layer/53309-river-flows/metadata/>

Design flow criteria to be assumed for the sites of potential hydro generation was determined in consultation with industry hydropower experts. For schemes with short penstock distances (of less than 1km), it was considered that the power station would likely be designed on a higher probability flow – possibly as high as the 80th percentile flow. The logic being that a shorter and consequently lower conveyance route cost, could accommodate a greater maximum power station design flow and output capacity. For schemes with longer conveyance routes and cost, a balance would have to be met between the increased costs associated with the longer conveyance route and the maximum power station design flow. For such schemes, the design flow would likely be lower, and a 65th percentile flow was deemed appropriate.

A formula was devised to estimate the 65th and 80th percentile flows from the mean flows in the River Flows dataset. However it was identified that this method was not ideal as it would potentially over or under estimate flows and that the magnitude of error may be more pronounced in smaller catchments and may also be impacted by the different geographic regions of New Zealand. Contact was made with NIWA, who provided a more detailed dataset¹⁶ containing the entire range of probability flows (in addition to the variables contained in the river flows dataset) for each of the 576,000 stream segments. Using this ‘Percentile Flows’ dataset removed a source of potential error by having access to actual modelled percentile flows for each stream segment as opposed to estimating these from mean flows.

It is also necessary to make an allowance for a minimum residual/environmental flow downstream of the intake location. Although there isn’t a prescribed formula for determining appropriate residual flows downstream of hydro scheme intakes - these would be dependent on the ecological requirements and determined on a case-by-case basis by the relevant consenting authority, discussions with consultant ecological hydrologists revealed that the most widely accepted information is described in the Proposed National Environmental Standard on Ecological Flows and Water Levels (2008). This recommends the following residual flows:

- For rivers and streams with mean flows less than or equal to 5 m³/s, a minimum flow of 90% of the mean annual low flow (MALF) as calculated by the Regional Council.
- For rivers and streams with mean flows greater than 5 m³/s, a minimum flow of 80% of MALF as calculated by the Regional Council.

The resulting formula for calculating the maximum power station generation is as follows;

Max Output = *design flow* * h_{net} * gravity * η where;

For mean flows ≤ 5 m³/s;

- ***design flow*** = 80% flow for penstock lengths < 1km and subtracting 90% of the 7 day MALF as a residual/environmental flow
- ***design flow*** = 65% flow for penstock lengths ≥ 1 km and subtracting 90% of the 7 day MALF as a residual/environmental flow

For mean flows > 5 m³/s;

- ***design flow*** = 80% flow for penstock lengths < 1km and subtracting 80% of the 7 day MALF as a residual/environmental flow
- ***design flow*** = 65% flow for penstock lengths ≥ 1 km and subtracting 80% of the 7 day MALF as a residual/environmental flow

h_{net} = the net head ($h_{net} = h_{gross} * 0.9$)

g = gravity (9.81 m/s²)

η = the product of all of the other component efficiencies, being 75% (as described in Section 3).

¹⁶ This dataset is referred to as the Percentile Flows dataset

Conveyance distance

To identify the distance over which the head criteria must be met, a list of existing small-scale schemes greater than 1MW in capacity, and where information on conveyance distance¹⁷ was available, was compiled, as described in Table 1.

Table 1 Conveyance lengths for a selection of operational small-scale hydro schemes in New Zealand

Owner/Operator	Name	Capacity (MW)	Conveyance length (km)
Northpower	Wairua	5	3
Pioneer Energy	Horseshoe Bend	4.3	1
Pioneer Energy	Kowhai	1.9	1.3
Pioneer Energy	Matiri	4.8	2.2
Pioneer Energy	Roaring Meg lower	3	2.4
Pioneer Energy	Fraser	2.8	4.5
Southern Generation	Upper Fraser	8	3.5
Trust House Ltd	Kourarau	1	0.8
Trustpower	Toronui	1.4	0.7
Trustpower	Rimu	2.4	2
Trustpower	Motukawa	5	3
Westpower	Amethyst	7.6	2.5

The information collated on conveyance distance shows a large range; 700m (Toronui) to 4.5km (Fraser) - with the majority being less than 3km. As such, a maximum length of 5km was adopted, on the basis that a combined penstock/channel conveyance distance greater than 5km was probably going to render sites uneconomic. Note that the actual distances used for the analysis ranged between 3-5km, depending on the river flow volume, as described in the following section.

4.1.2. GIS modelling process (Step 2)

The GIS process to identify sites that met the criteria described in Step 1 was developed by consultancy Critchlow Geospatial (Critchlow), following a workshop to discuss the approach. The code is listed in Appendix B, but in summary, the relationship between head and flow that was employed to identify potential locations of hydro power generation is described as follows;

- 0.3 – 0.4 cumecs and head > 350m and distance < 3km
- 0.4 – 0.5 cumecs and head > 280m and distance < 3km
- 0.5 – 0.6 cumecs and head > 250m and distance < 3km
- 0.6 – 0.8 cumecs and head > 190m and distance < 3km
- 0.8 – 1.0 cumecs and head > 160m and distance < 3km
- 1.0 – 1.5 cumecs and head > 120m and distance < 4km
- 1.5 – 2.0 cumecs and head > 100m and distance < 4km
- 2.0 – 5.0 cumecs and head > 70m and distance < 5km
- 5.0 – 10 cumecs and head > 50m and distance < 5km
- 10 – 20 cumecs and head > 30m and distance < 5km
- >20 cumecs and head > 20m and distance < 5km

Note that the minimum threshold of generation capacity to be identified by the GIS process increases for larger river flows. For river flows exceeding 5 cumecs, the minimum threshold is 1.66MW, for 10 cumecs the minimum threshold is 2MW and for 20 cumecs the minimum threshold is 2.7MW. The reason for this increase in minimum size requirement is because it was deemed unlikely that schemes as small as 1MW would be contemplated for such large flows – as the economics of the scheme would unlikely be attractive enough unless the generating capacity was higher.

¹⁷ The conveyance distance is a combination of channel and penstock – as that schematically shown in Figure 3.

The script process developed by Critchlow is described in Appendix C. The first step transforms the NIWA Percentile Flows dataset, which is comprised of river segments as lines, into points (or nodes). The script ‘stamps’ a node every 200m, or at shorter intervals where tributaries join (i.e. where river flows increase in volume). Figure 5 shows an example of the data stamp interval for a river near Wellington. In this example, a river with a 65th percentile flow exceeding 0.3 cumecs (dark blue line) has been identified from the NIWA Percentile Flows dataset (light blue lines) and data ‘stamped’ on a 200m interval (or more frequent where tributaries join).




Figure 5 Example of point/node frequency along a river near Wellington.

The maximum 200m interval was determined as being an appropriate balance between maintaining data accuracy and ensuring file sizes were not the excessively large. The relevant flow information was then extracted from the NIWA provided Percentile Flows dataset and recorded at each node. The elevation at each node was then obtained from the LINZ 8m DEM dataset.

Due to the volume of information, the New Zealand river network was first divided into different regions, based on the Regional Council boundaries. Even in doing so, the size of the datasets generated were immense (in some cases in excess of 100 GB) and took many hours to process. The West Coast region had to be split into two parts to be able to complete the analysis successfully.

The next part of this process was to use network (routing) analysis tools to interrogate the various criteria listed in Appendix B for each node out to a maximum distance of 3km for flows < 1m³/s, 4km for flows between 1-2 m³/s, and 5km for flows > 2 m³/s. The reason for the differences in conveyance distance for increasing flows was partly to help reduce data size and processing time but also to reflect hydro scheme construction in practise. It is unlikely that a scheme with a flow of less than 1 m³/s would be economically viable if the channel/penstock conveyance length is greater than 3km. Whereas, for larger river flows, there are more likely to be economically attractive opportunities that have longer channel/penstock conveyance routes, due to the economies of scale – especially given that higher generation capacity thresholds have been intentionally required for rivers with high flows.

Figure 6 shows the magnitude of the modelling challenge by plotting the mean river flows¹⁸ for the Hawkes Bay vicinity that exceed 0.3 cumecs – with flow ranges distinguished as per the script code. Figure 7 shows the same extent but plots all river segments (i.e. including those with mean flows less than 0.3 cumecs).

¹⁸ Although 65th and 80th percentile flows were used in the analysis, mean flows have been plotted for convenience – noting that for many rivers the mean flow will be within the range of 65 – 80th percentile flow.




Figure 6 Spatial extent of the River Flow dataset showing mean flows > 0.3 cumecs in Hawkes Bay vicinity




Figure 7 Spatial extent of the River Flow dataset for all rivers in Hawkes Bay vicinity.

The next part of the script process identifies the start and end elevations for every possible variation in stream length over the positive results identified in the previous process and calculates the grade, head and 'generation per kilometre'.

At the completion of this Step 2 process, the size of datasets was substantially reduced, but the larger regions still contained between 5,000 to 10,000 potential development 'candidates'.

4.1.3. Automated thinning exercise (Step 3)

A thinning exercise was devised to reduce the number of locations identified during Step 2, to identify the optimal results. Potential candidates were thinned on the following basis:

Thinning Phase 1: An automated script process that identifies the 'best' result for every specific river segment ID over a maximum distance of 1200m¹⁹. The parameter used to compare results was 'generation per kilometre' with the highest values being selected.

Thinning Phase 2: An automated script process that compares results with neighbouring river segments to identify the 'best-of' results across adjacent river segments by comparing the 'generation per kilometre' parameter over a maximum distance of 900m²⁰.

At the completion of Step 3, potential 'candidates' for each region typically ranged between 100 – 1000 in number. Attempts were made to reduce the size of the datasets through automated filtering, but more aggressive automated thinning processes resulted in potentially valid locations being incorrectly removed.

4.1.4. Manual filtering exercise (Step 4)

As described previously, the final step was a manual process, undertaken to review the potential candidates identified at the completion of Step 3 to produce a final dataset of potential small-scale run-of-river hydro generation sites.

This manual filtering involved:

- Removing sites within National Parks.
 - The Department of Conservation dataset, from which National Parks can be identified, was obtained from the Koordinates website²¹.
- Removing sites within rivers subject to NWCO.
 - The identification of sections of rivers subject to NWCO was done by interpreting the descriptions in the NWCO hearing decisions that can be found on the MfE website²².
- Removing sites coincident with hydro generation already in operation.
 - A Google Earth file identifying the locations of existing small-scale hydro generation and a list containing key information on each operational scheme was provided by the Independent Electricity Generators Association (IEGA). As the Google Earth file was dated 2012, schemes that had been constructed since then were identified and added. A spreadsheet containing limited information on these operational schemes was also

¹⁹ 1200m was deemed to be an appropriate maximum distance for this filter as it was considered unlikely two valid sites of generation would be present over the same river segment for distances less than this.

²⁰ Although it would have been preferable to compare the 'best of' stream segment results over a greater distance, 900m was deemed to be the appropriate maximum distance as any greater than this increased the risk of comparing potential 'candidates' on adjacent rivers and thus inadvertently removing potentially valid opportunities of hydro generation.

²¹ <https://koordinates.com/layer/754-doc-public-conservation-areas/>

²² <https://www.mfe.govt.nz/fresh-water/water-conservation-orders/existing-water-conservation-orders>

provided by IEGA and updated as required (see Appendix D). Of the 78 existing small-scale hydro schemes listed in Appendix D, 55 are greater than or equal to 1MW.

- Identifying the optimal site where two or more potential results are not compatible with each other and removing those sites that are sub-optimal.
 - Where groups of potential candidates were in close proximity and clearly not compatible
- Removing sites that are considered logistically impractical from an access or construction perspective.
 - This subjective assessment was made in consideration of topography, proximity to existing road network, difficulty in access to the intake location, difficulty in penstock route (based on topography), difficulty in location of powerhouse (i.e. if powerhouse location could only be located in a steeply incised channel) and assumed distance from local distribution network assets²³.

This manual filtering process significantly reduced the number of potential candidates to produce a final list that not only meets the power generation criteria, but one that has also been scrutinised through a constructability lens.

5. Literature review

A literature review was undertaken to determine whether previous studies had identified new potential hydro generation opportunities. Most studies concerned large-scale opportunities and as such were not relevant to this assessment of small-scale embedded opportunities. However, one study, undertaken in 2004 by East Harbour Management Services (EHMS), contained a comprehensive summary of potential new hydro opportunities throughout New Zealand, including large scale impoundment schemes, smaller run-of-river schemes and irrigation schemes. In summarising the information in the EHMS report to identify potential new run-of-river hydro generation schemes, the following rationale was applied:

- Discarding those opportunities that have been constructed.
- Discarding those opportunities also identified through the GIS modelling.
- Discarding those opportunities involving large dams.
- Discarding those opportunities considered highly unlikely to receive resource consent approval.

The resultant list of sites represents those opportunities that could be considered in addition to the list of sites identified through the GIS modelling.

6. Results

Table 2 lists the potential projects identified through the GIS modelling process described in Section 4. 84 potential schemes have been identified, which have been grouped by the Regional Council area in which they are located. Table 3 summarises the same information, but with the results aggregated by region council area. An estimate of generation (in GWh/annum) has been made based on an assumed capacity factor of 65%. This capacity factor was calculated by averaging the capacity factors for operational small-scale hydro schemes greater than 1MW where such information was able to be obtained from scheme owners.

²³ It had been intended that GIS information from each of the Electricity Distribution Businesses (aka “Network/Lines Companies”) would be obtained during the study and used as a criterion on which to filter out unfeasible sites due to distance from existing line assets. However, only a small number of Lines Companies provided the information, and as such, this method of filtering sites was not possible, other than via a conservative estimate of distance from where existing assets are anticipated to be located.

Table 2 List of potential small-scale hydro schemes identified through GIS modelling

ID	Region	River Channel Length (km)	Straight Line Length (Km)	Power Station Flow (m ³ /s)	Head (m)	Capacity (MW)	Generation (GWh/annum)	DOC Land Classification	Distance to nearest road (km)
1	Northland	4.1	3.1	11.8	44	3.5	19.7	Marginal Strip	<2
2	Waikato	3.4	2.6	1.2	132	1.0	5.8	Conservation Area	<2
3	Waikato	3.7	3.0	1.1	138	1.0	5.5	Marginal Strip	<2
4	Waikato	0.9	0.5	2.8	87	1.6	9.2	Marginal Strip	<2
5	Waikato	3.4	2.2	2.2	93	1.3	7.6		6.7
6	Waikato	4.7	3.6	2.0	79	1.1	6.1		<2
7	Waikato	0.8	0.7	3.3	60	1.3	7.4		<2
8	Waikato	0.6	0.5	3.9	59	1.5	8.6	Reserve	<2
9	Waikato	0.7	0.5	13.3	48	4.2	24.1		<2
10	Waikato	2.0	1.7	11.9	44	3.5	19.8		<2
11	Bay of Plenty	4.0	3.3	1.1	130	1.0	5.5		<2
12	Bay of Plenty	1.6	1.2	15.1	42	4.2	23.9		<2
13	Bay of Plenty	2.1	1.7	23.9	20	3.2	18.2	Reserve	<2
14	Bay of Plenty	3.4	3.1	20.2	21	2.8	15.7		9
15	Bay of Plenty	0.8	0.6	11.6	41	3.1	17.8		<2
16	Bay of Plenty	1.0	0.8	4.9	96	3.1	17.8	Reserve	<2
17	Bay of Plenty	3.6	2.9	10.7	30	2.1	12.2		5.4
18	Bay of Plenty	2.7	2.2	10.3	40	2.7	15.6		<2
19	Gisborne	4.6	3.2	23.5	21	3.3	18.7		<2
20	Gisborne	3.8	2.8	1.6	100	1.1	6.0		<2
21	Gisborne	0.8	0.7	2.6	70	1.2	6.8		3
22	Gisborne	4.4	2.5	12.5	43	3.6	20.4		<2
23	Gisborne	1.6	1.3	12.2	36	2.9	16.7	Marginal Strip	<2
24	Hawkes Bay	0.9	0.7	2.6	91	1.6	9.0		<2
25	Hawkes Bay	4.2	3.0	13.3	40	3.6	20.3		2.3
26	Hawkes Bay	3.8	2.6	6.4	96	4.1	23.4		<2
27	Hawkes Bay	2.9	1.6	26.0	21	3.7	21.1		<2
28	Hawkes Bay	2.3	1.4	11.3	40	3.0	17.0		<2
29	Hawkes Bay	0.8	0.7	9.9	42	2.7	15.6		2.9
30	Manawatu-Wanganui	2.6	0.3	22.3	20	3.0	17.2		<2
31	Manawatu-Wanganui	3.8	2.7	55.4	20	7.4	41.9	Marginal Strip	<2
32	Manawatu-Wanganui	3.9	3.0	1.0	183	1.2	7.1		<2
33	Manawatu-Wanganui	0.8	0.6	3.1	95	2.0	11.2	Conservation Area	5.6
34	Manawatu-Wanganui	4.1	2.0	5.4	63	2.3	12.8		<2
35	Manawatu-Wanganui	2.9	2.0	5.3	60	2.1	12.0	Conservation Area	<2
36	Manawatu-Wanganui	3.5	2.5	9.6	59	3.8	21.5	Marginal Strip	<2
37	Manawatu-Wanganui	3.0	1.3	10.7	31	2.2	12.7		<2
38	Manawatu-Wanganui	2.9	1.7	14.6	42	4.0	22.9		<2
39	Manawatu-Wanganui	3.2	2.0	13.4	40	3.6	20.3		<2
40	Taranaki	4.1	1.8	40.4	21	5.6	31.7		<2
41	Taranaki	5.0	2.7	25.6	21	3.5	19.9		<2
42	Taranaki	3.4	2.3	2.0	72	1.0	5.5		<2
43	Taranaki	4.5	3.1	11.4	40	3.1	17.4		<2
44	Taranaki	3.4	2.3	10.3	38	2.6	14.7		<2
45	Wellington	4.2	3.4	21.5	23	3.3	18.8		<2
46	Wellington	3.9	3.0	13.3	35	3.1	17.8		<2
47	Wellington	5.0	4.1	19.1	35	4.4	25.1		<2
48	Wellington	4.9	4.0	13.7	31	2.8	15.9		<2
49	Tasman-Nelson	0.9	0.7	2.1	141	1.9	11.1	Conservation Area	8.1
50	Tasman-Nelson	3.8	2.7	23.2	42	6.5	37.1	Marginal Strip	<2
51	Tasman-Nelson	2.9	2.3	1.0	165	1.0	6.0	Conservation Area	4.6
52	Marlborough	3.4	2.5	5.8	60	2.3	13.1	Marginal Strip	<2
53	Marlborough	3.5	2.8	1.2	120	1.0	5.5	Marginal Strip	10.7
54	Marlborough	4.2	2.9	10.8	32	2.3	13.1	Marginal Strip	<2
55	West Coast	4.7	3.0	2.5	90	1.5	8.6	Reserve	4.5
56	West Coast	0.8	0.6	2.3	125	1.9	10.8	Conservation Area	<2
57	West Coast	2.0	1.6	5.4	58	2.1	11.8	Conservation Area	3.1
58	West Coast	2.9	2.4	36.5	27	6.7	37.9		<2
59	West Coast	0.8	0.6	4.4	80	2.3	13.2	Reserve	<2
60	West Coast	3.5	2.4	63.2	21	8.7	49.6	Conservation Area	<2
61	West Coast	3.4	2.6	62.2	20	8.3	47.5		<2
62	West Coast	0.8	0.7	4.2	97	2.7	15.5	Conservation Area	8.4
63	West Coast	0.8	0.8	2.0	105	1.4	7.8	Conservation Area	13.3
64	West Coast	3.4	2.4	1.8	126	1.5	8.6	Conservation Area	<2
65	West Coast	1.0	0.9	9.7	42	2.7	15.3	Conservation Area	2.8
66	West Coast	0.8	0.7	1.8	104	1.3	7.2	Reserve	<2
67	West Coast	0.9	0.8	4.1	74	2.0	11.5	Conservation Area	3
68	West Coast	0.8	0.8	4.4	91	2.6	15.0	Conservation Area	<2
69	West Coast	3.4	3.0	34.7	26	6.0	34.2	Conservation Area	<2
70	West Coast	3.2	2.8	10.8	33	2.4	13.5	Conservation Area	<2
71	West Coast	1.0	0.9	4.1	56	1.5	8.7	Conservation Area	<2
72	Canterbury	3.8	2.4	1.3	134	1.2	6.7		2.5
73	Canterbury	3.7	2.7	63.1	20	8.5	48.3		<2
74	Otago	0.9	0.7	2.2	117	2.0	11.2		<2
75	Otago	3.0	2.4	0.9	162	1.1	6.1		<2
76	Otago	2.1	1.7	5.9	59	2.6	15.0		2.4
77	Southland	1.0	0.9	1.8	94	1.8	10.1	Marginal Strip	6.6
78	Southland	0.9	0.8	1.7	76	1.7	9.5	Marginal Strip	4.6
79	Southland	0.8	0.7	1.9	101	1.9	11.0	Marginal Strip	5.5
80	Southland	0.8	0.7	2.4	71	2.4	13.6	Marginal Strip	3.8
81	Southland	1.0	0.9	1.6	71	1.6	9.0	Marginal Strip	3.6
82	Southland	3.7	2.6	4.3	93	4.3	24.7	Conservation Area	<2
83	Southland	5.0	2.9	1.5	91	1.5	8.4	Conservation Area	5
84	Southland	1.0	0.9	1.4	87	1.4	8.2	Conservation Area	4.8
TOTAL						236	1346		

Table 3 Summary of potential small-scale hydro schemes by Region

	Number of Potential Schemes	Total Capacity Potential (MW)	Total Generation Potential (GWh/annum)	Average scheme size	Max scheme size	Min scheme size	Number within DOC land	Number outside DOC land
Northland	1	3.5	19.7	3.5	3.5	3.5	1	0
Auckland								
Waikato	9	16.5	94.0	1.8	4.2	1.0	4	5
Bay of Plenty	8	22.3	126.7	2.8	4.2	1.0	2	6
Gisborne	5	12.0	68.6	2.4	3.6	1.1	1	4
Taranaki	5	15.7	89.3	3.1	5.6	1.0	0	5
Manawatu-Wanganui	10	31.5	179.6	3.2	7.4	1.2	4	6
Hawkes Bay	6	18.7	106.4	3.1	4.1	1.6	0	6
Wellington	4	13.6	77.6	3.4	4.4	2.8	0	4
Tasman-Nelson	3	9.5	54.2	3.2	6.5	1.0	3	0
Marlborough	3	5.6	31.7	1.9	2.3	1.0	3	0
West Coast	17	55.6	316.7	3.3	8.7	1.3	15	2
Canterbury	2	9.7	55.0	4.8	8.5	1.2	0	2
Otago	3	5.7	32.3	1.9	2.6	1.1	0	3
Southland	8	16.6	94.5	2.1	4.3	1.4	4	4
Total	84	236	1346	2.8	8.7	1.0	37	47

Also noted in Table 2 is whether a particular site is within DOC land, and if so, the type of that land classification. It is possible that obtaining resource consent approval for locations within DOC land may be more difficult or have greater limitations in regard to water take than for other locations, however this has not been quantified for this study. The distance to the nearest existing road has also been calculated. This can be a helpful parameter in understanding the magnitude of additional costs that could be faced with construction of new roads accessing the site location – which may lessen the attractiveness of a site, from an economic perspective. The manual filtering process, described in Section 4.1.4, also filtered out sites that would be significant distances from existing roads.

In assessing the results, it is not surprising that so few potential sites were identified in Northland and that none were identified in Auckland - neither of these regions have significant hydro power potential – partly due to the topography that is characteristic over much of this part of New Zealand. At the completion of the automated filtering process, there were no potential sites identified in the Auckland Region and just three potential sites in Northland. The Northland sites were reduced to one during the manual filtering process – with one being discarded due to coincidence with an existing scheme (the 5MW Wairua scheme, owned and operated by Northpower) and another being discarded as it was deemed to be logistically impractical.

In contrast, it is surprising that there were not more sites identified in the Otago and Canterbury regions. This is likely to be due to the limitations of the GIS modelling - which can ‘miss’ opportunities, as described in Section 7, and/or could have been due to potential opportunities being inadvertently discarded during the manual filtering process due to an overly harsh assessment of the access or construction logistics.

This premise is somewhat endorsed when comparing the GIS modelling to those sites identified through the literature search, described in Section 5. Table 4 lists those opportunities identified in the EHMS (2004) report that were not identified through the GIS modelling and as such could be considered as additional opportunities to those listed in Table 2. Many of these schemes involve longer conveyance lengths than the criteria allowed for in the GIS modelling and assume a degree of storage that was not able to be considered in the GIS modelling. Also, most are high flow, low head schemes – which are the types of schemes that are more likely to be missed by the GIS modelling due to the inherent inaccuracies of the DEM that are more pronounced when comparing small differences in elevation.

Table 4 Summary of potential small-scale hydro schemes identified by EHMS (2004)

ID	Region	Capacity (MW)	Generation (GWh/annum)
EHMS 1	Waikato	7	39.9
EHMS 2	Manawatu - Wanganui	7	39.9
EHMS 3	Hawkes Bay	10	56.9
EHMS 4	Wellington	9	51.2
EHMS 5	West Coast	5	28.5
EHMS 6	West Coast	7	39.9
EHMS 7	West Coast	8	45.6
EHMS 8	Canterbury	12	68.3
EHMS 9	Canterbury	6	34.2
EHMS 10	Canterbury	11	62.6
EHMS 11	Otago	6	34.2
EHMS 12	Otago	6	34.2
EHMS 13	Otago	8	45.6
EHMS 14	Southland	5	28.5
	Total	107	609

Note: A capacity factor of 65% has been assumed in the calculation of annual generation

In summary, the 84 locations identified through the GIS modelling could contribute an estimated 236 MW of capacity and 1346 GWh/annum generation. The literature search suggests there may be another 14 locations that could be considered as being potential hydro power opportunities. These would add a further 107 MW capacity and 609 GWh/annum generation – giving a combined 98 locations, 343 MW capacity and almost 2,000 GWh/annum generation. In total, these theoretically possible opportunities represent a significant number of as yet undeveloped potential small-scale hydro power schemes – more than the number of small-scale schemes that have been constructed in New Zealand to date. However, given the spread of sites across New Zealand and the estimated total generating capacity of just 343MW, it is unlikely small-scale hydropower generation will provide a great deal of support to meeting future demand growth.

Furthermore, an assessment of the consentability or the ability to secure access rights to the land has not been undertaken and indeed site visits would be required before any locations can be confirmed as being appropriate for development. Almost half of the locations are within DOC administered land which may result in greater consenting challenges or a requirement for maintaining higher residual/environmental flows downstream of the intake locations. It would be unreasonable to assume that all of the sites would be ultimately deemed appropriate for development and be progressed for construction. Indeed, discussions with an experienced developer of small-scale hydropower schemes in New Zealand suggests that the number of these theoretically possible opportunities that would actually be constructed is likely to be just a fraction of the total identified during this study.

7. Data Limitations

Using GIS to identify potential sites for small-scale hydro generation is achievable and the methodology employed worked well in identifying potential hydro power opportunities, including the identification of a high proportion (approximately 80%) of the existing sites of run-of-river hydro power exceeding 1MW capacity also being identified through the modelling.

However, there are limitations in using GIS, and the modelling is only as good as the data upon which it is based. Any errors or uncertainty in either the River Flows dataset or the DEM elevation data will lead to inaccuracies in the modelling results, and this will be manifested by:

- Invalid sites being identified.
- Valid sites that are not identified (noting that this could also be due to the conveyance distance criteria being too short).
- Valid sites identified, but not at their correct generation capacity potential.

River flow

It is unreasonable to assume that the modelling of river flows throughout New Zealand based on 485 discrete locations, as was undertaken by NIWA to determine the River Flows (and Percentile Flows) datasets will represent all river flow characteristics accurately. Consequentially, there will almost certainly be locations where actual river flows are greater, or lower, than modelled flows. In such circumstances, the GIS modelling process may miss potential hydro power generation opportunities or may identify opportunities incorrectly.

While an assessment of the occurrence of this potential error was not undertaken during this study, it was recognised, during the manual thinning process, that there were two occurrences where it was noted that modelled flows did not align well with actual river flow. These were in relation to the Rimu scheme and the Toronui Scheme located in Hawkes Bay (owned and operated by Trustpower). These schemes (especially the Rimu) have high head and low flow and have generation capacities of approximately 2.4MW and 1.4 MW respectively.

Interrogation of the NIWA Probability Flow dataset revealed that the 65th percentile flows at the Rimu and Toronui intakes are 0.24 m³/s and 0.16 m³/s respectively. These flows are lower than the minimum flow criteria prescribed in the GIS script (see Appendix B). As such, these sites could not have been identified by the modelling process. However, actual 65th percentile flows at the intakes of these schemes is almost 50% greater for the Rimu and almost 100% greater for the Toronui²⁴. The likely reason why the NIWA modelled data under-estimates flows at these locations is probably due to the fact that both the Rimu and Toronui schemes are located on spring fed rivers which have higher than 'normal' flows given their catchment areas. The modelling undertaken by NIWA to estimate the river flows would not have been able to consider this level of site specific detail, especially so far up in the catchment (and so far from the hydrological stations upon which the extrapolations are based).

Another issue is that the maximum power station flows for the Rimu and Toronui schemes are 1 m³/s and 1.2 m³/s respectively. These design flows are significantly greater than the actual 65th percentile (or even the 80th percentile) flows and thus even if the minimum flow constraint in the modelling process had been set to a lower flow limit, the calculated generation capacity, assuming a 65th percentile flow, would not have exceeded 1MW and thus they would not have been identified as potential sites of hydro power generation.

Head calculation

There are two main sources of potential error in regard to the calculation of the head for a location of potential hydro power generation. The first is the inherent inaccuracy of the LINZ 8m DEM, which, as noted by LINZ, and as described in Section 4.1.1, is ± 22 metres horizontally and ± 10 metres vertically. The difference of a few metres of head could cause some valid locations to be missed, or to identify locations that are not valid.

The second source of potential error is in the correlation of the NIWA digitised river channels with the river channels as determined by the DEM. Figure 7 is an image showing the colour graduated elevation based on the DEM and the digitised river channels as contained in the NIWA River Flows dataset. As can be seen, in general the digitised river channels align closely with the DEM, however there are instances where the correlation between the datasets is not as accurate as desired (as identified on Figure 7).

Errors in calculation of river channel elevation could result where the two datasets do not align closely, and this would be manifested in the river elevation increasing and appearing to go uphill at such locations. Given that the modelling process first transformed the digitised river channels into points every 200m (or less where river tributaries join) the likelihood of this type of error is somewhat mitigated, but nonetheless remains a potential source of error. This type of error is more likely to occur at locations of high flow and low head – where gradients are low and river channels are meandering.

²⁴ Based on advice from Trustpower




Figure 7 Correlation between the NIWA River Flows digitised river channels and the LINZ 8m DEM, indicating locations of suboptimal correlation (circled red).

Storage

Many small hydro power schemes in New Zealand have some degree of storage associated with them – as the benefits of storage, even if only modest, can greatly improve the project economics. Having storage would likely mean that the maximum power station design flow would be greater (giving an increased maximum generating capacity) and annual generation would likely also be greater, due to the ability to capture and store flows that would otherwise be spilled during high flow events. This potential issue has already been highlighted by the Toronui scheme example described previously, but almost certainly will be an issue for any locations with storage potential. However, it was not possible to model the potential for storage as part of the GIS modelling exercise undertaken for this study. The scope of the objective and the available datasets that were used in the analysis made such an assessment too difficult. As such, this remains another potential source of error where potential opportunities could have been missed.

Conveyance distance

Constraining the distance over which to assess the potential for the 1MW generation criteria to be met is another potential source of error. As noted in Section 4.1.1, an assumption had to be made as to what the appropriate maximum conveyance distance should be. While the conveyance distance criteria selected has sound logic behind it (and is based on actual distances for existing small-scale hydro schemes) there remains the possibility that some opportunities, particularly those with high flow and low head which have long diversion channels, could be missed. It is likely that some of the potential schemes described in the 2004 EHMS report would have been identified by the GIS modelling process if a longer conveyance distance had been adopted.

GIS process data interval

As described in Section 4.1.2 the data in the River Flow dataset was transformed from line information to point information in order for the routing script to function properly. Clearly, the greater the point

density, the greater the data quality – but also the larger the file size. As such a balance had to be found between data quality and file size. A point interval of 200m was ultimately selected as being an appropriate interval, with additional points wherever tributaries intersect. Given that the river segment lengths range from 30m to 29km (see Section 4.1.1), this will mean that there will be some reaches where points are as close as 30m to each other. It will also mean that there are some reaches where the distance between points is consistently 200m for significant distances.

While this data interval is not of concern from a river flow perspective – in fact it means that every location where river flows change will be captured – it does mean that there may be occurrences where there is a ‘smoothing’ of elevation given that data from the DEM will, for some stretches of river, only be taken every 200m. This may result in less accurate calculations of head, grade and generation per kilometre. However, the magnitude of this potential error is low, and the consequence is minor.

8. Final thoughts

The combined capacity and annual generation potential of identified small-scale hydro power opportunities is not at a level which suggests they could play a significant part in meeting New Zealand’s future demand growth. It is also a ‘mature’ technology, and thus one that is unlikely to see a decline in future costs per installed capacity, such as is the case with other technologies such as wind and solar where technology improvements are continuing to decrease the capital costs. As such, small-scale hydro power generation is likely to be at a disadvantage, from an economic perspective, in comparison to wind and solar generation.

However, embedded generation projects can be eligible for Avoided Cost of Transmission (ACOT) payments, which can improve project economics. Additionally, in some areas, small-scale hydro power could help with meeting electricity demand at a local level and also provide network stability. The value of this should not be underestimated, especially if modest storage is available and higher capacity factors are possible than that assumed, enabling generation to be provided to the network for significant occurrences of time.

It should also be noted that there are likely to be many more potential opportunities of hydro power schemes throughout New Zealand that would generate less than 1MW. Although the identification of such schemes were outside of the scope of this particular study, it is safe to assume that, collectively, these opportunities are also unlikely to provide a significant amount of new generating capacity and annual generation to meet New Zealand’s future demand growth.

9. About the authors

The research was undertaken by Steve Harding and Graeme Mills of Roaring 40s Wind Power Ltd (R40s) with assistance and input by a number of industry experts. GIS analysis and advice was provided by Critchlow Geospatial with direction by R40s.

R40s was formed in 2018 to provide consultancy services to organisations wanting to identify, investigate and develop renewable energy projects. Our experience covers a wide range of project development aspects – site identification, land access negotiations, feasibility studies, resource modelling, project economic analysis, consent strategy and applications, consent hearings, stakeholder engagement, detail design studies and business case preparation.

Steve and Graeme have a significant amount of experience in hydropower investigations and operation, most of which was gained whilst working for ECNZ and Works/Opus Consultancy in hydrology-related fields. During his time at ECNZ Graeme was lead author of a number of studies that summarised the hydropower potential of New Zealand, including the identification and assessment of potential sites of new hydro generation. Steve was involved in securing the resource consent for the water take for the Rimu and Toronui hydro power schemes (constructed in 2013 and owned/operated by Trustpower) and is currently investigating a mini-hydro opportunity in Hawkes Bay that would be embedded to the local distribution network.

10. References

- Booker, D.J.; Woods, R.A. (2013) Comparing and combining physically-based and empirically-based approaches for estimating the hydrology of ungauged catchments. *Journal of Hydrology* DOI: 10.1016/j.jhydrol.2013.11.007.
- Booker, D.J. (2015). Hydrological indices for national environmental reporting. Prepared for Ministry for the Environment.
- Department of Conservation. DOC Public Conservation Areas. <https://koordinates.com/layer/754-doc-public-conservation-areas/>
- East Harbour Management Services (2004). Waters of National Importance – Identification of Potential Hydroelectric Resources. A report for the Ministry of Economic Development.
- Hatata, A.Y. (2019). A feasibility study of small hydro power for selected locations in Egypt. *Energy Strategy Reviews*. Volume 24, April 2019, pp 300-313. <https://www.sciencedirect.com/science/article/pii/S2211467X19300409>
- IPCC (2019). Accelerated electrification: Evidence, analysis and recommendations, Interim Climate Change Committee.
- Land Information New Zealand (LINZ) Data Service. NZ 8m Digital Elevation Model (2012) metadata <https://data.linz.govt.nz/layer/51768-nz-8m-digital-elevation-model-2012/metadata/>
- Ministry of Business, Innovation and Employment (2019). Electricity demand and generation scenarios: Scenario and results summary, Ministry of Business, Innovation and Employment.
- Ministry for the Environment. River Flows metadata. <https://data.mfe.govt.nz/layer/53309-river-flows/metadata/>
- Ministry for the Environment. Water Conservation Orders. <https://www.mfe.govt.nz/fresh-water/water-conservation-orders/existing-water-conservation-orders>
- Nasir, B.A. (2014). Design Considerations of Micro-hydro-electric Power Plant. *Energy Procedia*. Volume 50, 2014, pp19-29. <https://www.sciencedirect.com/science/article/pii/S1876610214007395>
- New Zealand Productivity Commission (2018). Low-emissions economy – Final Report.
- Parsons Brinckerhoff (2012). 2011 NZ Generation Data Update. A report for the Ministry of Economic Development.
- Transpower (2018). Te Mauri Hiko - Energy Futures (White Paper), Transpower, New Zealand.
- Transpower (2020). Whakamana i te Mauri Hiko – Empowering our Energy Future, Transpower, New Zealand.
- www.nzas.co.nz. NZAS terminates electricity contract and plans to wind-down operations following strategic review. Notice to ASX/LSE (9 July 2020). https://www.nzas.co.nz/files/3413_2020070981142-1594239102.pdf
- www.statista.com. The world's largest hydroelectric dams as of 2019, based on generating capacity. <https://www.statista.com/statistics/474526/largest-hydro-power-facilities-in-the-world-by-generating-capacity/>
- Zhang, Q.; Smith, B. and Zhang, W. (2012). Small Hydropower Cost Reference Model. Oak Ridge National Laboratory.

Appendix A – National Water Conservation Orders (from the Ministry for the Environment)

Table of water conservation orders

Name	Reference number
Pre-RMA	
Motu River	1984/20 [New Zealand Legislation website]
Rakaia River	1988/241 [New Zealand Legislation website] National Water Conservation (Rakaia River) Amendment Order 2013 [New Zealand Gazette website]
Lake Wairarapa	1989/51 [New Zealand Legislation website]
Manganuioteao River	1989/52 [New Zealand Legislation website]
Lake Ellesmere	1990/155 [New Zealand Legislation website]
Ahuriri River	1990/156 [New Zealand Legislation website]
Grey River	1991/132 [New Zealand Legislation website]
Under the RMA	
Rangitikei River	1993/15 [New Zealand Legislation website]
Kawarau River	1997/38 [New Zealand Legislation website] 2013/450 (Water Conservation (Kawarau) Amendment Order 2013) [New Zealand Legislation website]
Mataura River	1997/126 [New Zealand Legislation website]
Buller River	2001/139 [New Zealand Legislation website]
Motueka River	2004/258 [New Zealand Legislation website]
Mohaka River	2004/397 [New Zealand Legislation website]
Rangitata River	2006 [New Zealand Gazette website]
Oreti River	2008/127 [New Zealand Gazette website]

Source: <https://www.mfe.govt.nz/fresh-water/water-conservation-orders/existing-water-conservation-orders/table-water-conservation>

Appendix B – Criteria for GIS modelling (Step 2)

PS_Flow_80 >= 0.3 and PS_Flow_80 < 0.4 and head > 350 and Distance < 1 into criteria0a

PS_Flow_65 >= 0.3 and PS_Flow_65 < 0.4 and head > 350 and Distance >= 1 and Distance < 3 into criteria0b

PS_Flow_80 >= 0.4 and PS_Flow_80 < 0.5 and head > 280 and Distance < 1 into criteria1a

PS_Flow_65 >= 0.4 and PS_Flow_65 < 0.5 and head > 280 and Distance >= 1 and Distance < 3 into criteria1b

PS_Flow_80 >= 0.5 and PS_Flow_80 < 0.6 and head > 250 and Distance < 1 into criteria2a

PS_Flow_65 >= 0.5 and PS_Flow_65 < 0.6 and head > 250 and Distance >= 1 and Distance < 3 into criteria2b

PS_Flow_80 >= 0.6 and PS_Flow_80 < 0.8 and head > 190 and Distance < 1 into criteria3a

PS_Flow_65 >= 0.6 and PS_Flow_65 < 0.8 and head > 190 and Distance >= 1 and Distance < 3 into criteria3b

PS_Flow_80 >= 0.8 and PS_Flow_80 < 1 and head > 160 and Distance < 1 into criteria4a

PS_Flow_65 >= 0.8 and PS_Flow_65 < 1 and head > 160 and Distance >= 1 and Distance < 3 into criteria4b

PS_Flow_80 >= 1 and PS_Flow_80 < 1.5 and head > 120 and Distance < 1 into criteria5a

PS_Flow_65 >= 1 and PS_Flow_65 < 1.5 and head > 120 and Distance >= 1 and Distance < 4 into criteria5b

PS_Flow_80 >= 1.5 and PS_Flow_80 < 2 and head > 100 and Distance < 1 into criteria6a

PS_Flow_65 >= 1.5 and PS_Flow_65 < 2 and head > 100 and Distance >= 1 and Distance < 4 into criteria6b

PS_Flow_80 >= 2 and PS_Flow_80 < 5 and head > 70 and Distance < 1 into criteria7a

PS_Flow_65 >= 2 and PS_Flow_65 < 5 and head > 70 and Distance >= 1 and Distance < 5 into criteria7b

PS_Flow_80 >= 5 and PS_Flow_80 < 10 and head > 60 and Distance < 1 into criteria8a

PS_Flow_65 >= 5 and PS_Flow_65 < 10 and head > 60 and Distance >= 1 and Distance < 5 into criteria8b

PS_Flow_80 >= 5 and PS_Flow_80 < 10 and head > 50 and head <= 60 and Distance < 1 into criteria8c

PS_Flow_65 >= 5 and PS_Flow_65 < 10 and head > 50 and head <= 60 and Distance >= 1 and Distance < 5 into criteria8d

PS_Flow_80 >= 10 and PS_Flow_80 < 20 and head > 50 and Distance < 1 into criteria9a

PS_Flow_65 >= 10 and PS_Flow_65 < 20 and head > 50 and Distance >= 1 and Distance < 5 into criteria9b

PS_Flow_80 >= 10 and PS_Flow_80 < 20 and head > 30 and head <= 50 and Distance < 1 into criteria9c

PS_Flow_65 >= 10 and PS_Flow_65 < 20 and head > 30 and head <= 50 and Distance >= 1 and Distance < 5 into criteria9d

PS_Flow_80 >= 20 and head > 40 and Distance < 1 into criteria10a

PS_Flow_65 >= 20 and head > 40 and Distance >= 1 and Distance < 5 into criteria10b

PS_Flow_80 >= 20 and head > 20 and head <= 40 and Distance < 1 into criteria10c

PS_Flow_65 >= 20 and head > 20 and head <= 40 and Distance >= 1 and Distance < 5 into criteria10d

Where;

- Flow is in cumecs (m³/s)
- Head is in metres (m)
- Distance is in kilometres (km)
- PS_Flow_65 is the 65% flow, adjusted for the removal of the 7 day MALF (as described in Section 4.1.1)
- PS_Flow_80 is the 80% flow, adjusted for the removal of the 7 day MALF (as described in Section 4.1.1)

Appendix C – GIS modelling script description (Step 2)

- 1) Create a network of nodes every 200m along all river channels in the Probability Flows dataset
- 2) Compile all the river flow information (PS_FLOW_65, PS_FLOW_80, mean flow, MALF) for each node
- 3) Using network (routing) analysis tools determine the matrix of potential routes from each point to all other points on the river network within a maximum distance of 5km (This generates multiple overlapping river sections for each point - generally in 200m increments)
- 4) Using the LINZ DEM determine the maximum, minimum elevations for every possible variation in stream length out to the maximum 5km length and calculate the grade and fall of every derived route (overlapping river sections)
- 5) Identify and remove non valid route options (where the routing analysis calculated uphill possibilities at stream confluences)
- 6) Calculate the generation potential on a per kilometre basis for every potentially valid route (this parameter was to be used to thin the results and help identify the optimal solutions)

APPENDICES



Appendix D – List of existing small-scale hydro schemes

Owner/Operator	Name	Capacity (MW)	Year Commissioned	Owner/Operator	Name	Capacity (MW)	Year Commissioned
A D Harwood	Upper Takaka	0.42		Pupu Hydro Society	Pupu	0.3	1929
Birchfield Minerals	Ngahere	0.1		Renewable Power Ltd	Normanby	1	1903, 2015
Brooklyn Electricity Ltd	Brooklyn	0.2	1934	Southern Generation	Upper Fraser	8	
Clearwater Hydro (The Lines Co)	Mangapehi	1.6	2008	Talla Burn Generation	Talla Burn	2.15	2010
Clearwater Hydro (The Lines Co)	Marokopa/Speedy's Rd	2	2011	Trust House Ltd	Kourarau	1	1925
Clearwater Hydro (The Lines Co)	Matawai	2	2009	Trustpower	Kaimai 5	0.35	1994
Counties Power	Mangatawhiri	0.2		Trustpower	Kanieri Forks	0.43	1911
Drysdale Hydro Company	Drysdale	0.1		Trustpower	Duffers	0.5	1928
Eastland Generation	Waihi Station	5	1986	Trustpower	McKays Creek	1.1	1931
Genesis Energy	Mangaio	1.8	2008	Trustpower	Hinemaiaia B	1.3	1966
Inchbonnie Hydro	Inchbonnie	1.7		Trustpower	Toronui	1.4	2013
Kawatiri Energy	Lake Rochfort	4.2	2013	Trustpower	Hinemaiaia A	2.4	1952
Kea Energy	Feredays Island	0.3	2005	Trustpower	Rimu	2.4	2013
King Country Energy	Piriaka	1	1924	Trustpower	Waihopai	2.4	1927
King Country Energy	Mokauiti	1.6	1925, 1938, 1963	Trustpower	Hinemaiaia C	2.8	1982
King Country Energy	Wairere	4.6	1925	Trustpower	Arnold	3	1932
King Country Energy	Kuratau	6	1962	Trustpower	Wahapo/Okārito Forks	3.1	1960
MainPower	Cleardale	0.9	2010	Trustpower	Dillmans	3.5	1928
Mercury	Maraetai (mini)	0.1		Trustpower	Argyle	3.8	1983
Niblick Trust	Mataura	0.9		Trustpower	Mangorei	4.5	1906, 1931
Northpower	Wairua	5	1916	Trustpower	Motukawa	5	1938
NZ Energy	Raetihi	0.53		Trustpower	Lower Mangapapa	5.6	1979
NZ Energy	Fox	0.5		Trustpower	Flaxy	2	1982
NZ Energy	Turnbull	0.9		Trustpower	Montalto	1.8	1958
Omanawa Falls Hydro Limited	Omanawa Falls	0.2	1915, extended 1921	Trustpower	Deep Stream	5	2008
Omanawa Falls Hydro Limited	Karaponga	0.55		Trustpower	Waipori 1A	10	1983
Onekaka Energy	Onekaka	0.94		Trustpower	Waipori 3	7.6	1952
Opuha Water / TrustPower	Opuha	7	1999	Trustpower	Waipori 4	8	1954
Opunake Power Ltd	Opunake	0.4		Trustpower	Paerau	10	1984
Palmerston North City Council	Turitea (hydro)	0.1		Trustpower	Patearoa	2.3	1984
Pioneer Energy	Oxburn/Glenorchy	0.4	1968	Trustpower	Kumara	6.5	1928
Pioneer Energy	George	1	1924	Trustpower	Wairau	7.2	1983
Pioneer Energy	Teviot Bridge Station	1.13	1972	Watercare Services	Mangatangi	0.6	
Pioneer Energy	Falls	1.3	2003	Westpower	Amethyst	7.6	2013
Pioneer Energy	Roaring Meg upper	1.3	1936				
Pioneer Energy	Michelle	1.6	1982				
Pioneer Energy	Wye Creek	1.7	1929				
Pioneer Energy	Kowhai	1.9	2010				
Pioneer Energy	Fraser	2.8	1956				
Pioneer Energy	Roaring Meg lower	3	1936				
Pioneer Energy	Horseshoe Bend	4.3	1999				
Pioneer Energy	Matiri	4.8	2020				
Pioneer Energy	Monowai	6.6	1926				
Pioneer Energy	Ellis Station	7.8	1981				

Notes:

- Original list provided by IEGA, with updates made as appropriate
- There are 78 schemes in total; 55 schemes > 1MW in capacity
- Pioneer's *Ellis*, *Horseshoe Bend*, *Michelle*, *George Teviot Bridge* and *Kowhai* are all part of the *Teviot Scheme*
- Pioneer's *Matiri* project is still under construction and intended to be commissioned in late 2020
- The total generation capacity is 215.2MW, however this includes Trustpower's Kaimai 5, Lower Mangapapa, Flaxy, Montalto, Deep Stream, Paerau, Patearoa and Waipori 1A, 3 and 4 – all of which are part of various collective schemes and treated as grid connected. If removed, the total existing embedded hydro generation capacity is 162.45 MW.

Appendix E – Locations of the 485 Hydrological Stations used by NIWA to extrapolate river flow parameters across New Zealand's river network

